


ONGOING SAFETY RECALL

Plastic Handle Fire Extinguishers

Hazard:

The fire extinguisher can become clogged or require excessive force to discharge. In addition, the nozzle can detach with enough force to pose an impact hazard.

This recall, which was announced in 2017, involves two styles of Kidde fire extinguishers: certain plastic handle fire extinguishers and push-button Pindicator fire extinguishers. This is not a new recall.



Description of Products:

The recall involves 146 models of Kidde plastic handle fire extinguishers manufactured between January 1, 1973 and August 15, 2017, including some models that were previously recalled in March 2009 and in February 2015.

Remedy for Both Fire Extinguisher Types:

Consumers should immediately contact Kidde for instructions regarding return of recalled fire extinguishers and to request a free replacement unit.

Consumer Contact: Kidde toll-free at

1-800-880-6788

from 8 a.m. to 8 p.m. EST Monday through Friday,
9 a.m. to 3 p.m. EST Saturday, or online at www.kidde.com and click on Product Safety Notices for more information.

Push-Button Pindicator Fire Extinguishers



Description of Products:

The recall involves eight models of Kidde push-button Pindicator fire extinguishers manufactured between August 11, 1995 and September 22, 2017. The no-gauge push-button extinguishers were sold in red and white, and with a red or black nozzle. These models were sold primarily for kitchen and personal watercraft applications.

Scan Code
with Mobile
Device for
More Info



Post through December 31, 2019

In cooperation with the U.S. Consumer Product Safety Commission